ALCO CONTROLS



Emerson Climate Technologies GmbH Am Borsigturm 31 D-13507 Berlin

MANUFACTURER DECLARATION

We hereby declare under our sole responsibility that the following products

T-, L-, 935-, ZZ-Series, TX6 ¹⁾	TIH, TX3-, TI-	TIH-, TX3- 1) - FLR
	Series, TX7, LIV 1)	(for R290)

¹⁾ followed by number indicates the capacity and the type of refrigerant

comply with the basic requirements of following **EU Directives**:

Pressure Equipment Directive 2014/68/EU

Fluid Group 2 according to PED 2)	Fluid Group 1 according to PED 2)
DN ≤ 32	DN ≤ 25
Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.	Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.
Conformity assessment: not applicable	Conformity assessment: not applicable

²⁾ for the full list of refrigerants see Operating Instructions

Applied harmonized standards:

EN 378-2: 2016 Refrigerating systems and heat pumps - Safety and environmental requirements.

Parts 2: Design, construction, testing, marking and documentation.

EN 12284: 2003 Refrigerating systems and heat pumps - Valves - Requirements, testing and

marking.

Signed for and on behalf of Emerson Climate Technologies GmbH:

Matthew Irons (Vice-President Engineering)

Aachen, June 01, 2020

Matthe Sean