

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	ATLANTIC GEOLIA 17	Reg. No.	012-C700083
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	ATLANTIC GEOLIA 17		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.3 kg		
Certification Date	16.10.2020		
Testing basis	HP Keymark Scheme Rules rev 8		

## Model: ATLANTIC GEOLIA 17

Configure model	
Model name	ATLANTIC GEOLIA 17
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

### Heating

EN 14511-4	
Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.63 kW	15.41 kW
El input	3.86 kW	5.50 kW
COP	4.31	2.80

### Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	55 dB(A)	55 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	177 %	134 %
Prated	19.00 kW	18.00 kW
SCOP	4.63	3.55
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	17.00 kW	15.70 kW
COP Tj = -7°C	4.48	2.97
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	17.10 kW	16.30 kW
COP Tj = +2°C	4.68	3.58
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	17.20 kW	16.70 kW
COP Tj = +7°C	4.88	3.95
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	17.30 kW	17.00 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	5.08	4.32
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	17.00 kW	15.70 kW
COP Tj = Tbiv	4.48	2.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.50 kW	15.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.22	2.74
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	90 W	90 W
PSB	3 W	3 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.70 kW	2.30 kW
Annual energy consumption Qhe	8604 kWh	10337 kWh

Water/Water Heat Pump

## Heating

This information was generated by the HP KEYMARK database on 22 Jun 2022

<b>EN 14511-4</b>	
Starting and operating test	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	22.13 kW	20.14 kW
El input	4.25 kW	5.69 kW
COP	5.21	3.54

## Average Climate

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	217 %	176 %
Prated	25.00 kW	23.00 kW
SCOP	5.63	4.60
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	21.80 kW	20.20 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = -7°C	5.42	3.76
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	22.00 kW	20.80 kW
COP Tj = +2°C	5.68	4.64
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	22.10 kW	21.20 kW
COP Tj = +7°C	5.94	5.18
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	22.80 kW	21.60 kW
COP Tj = 12°C	6.20	5.72
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	21.80 kW	20.20 kW
COP Tj = Tbiv	5.42	3.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	21.70 kW	19.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.29	3.54
WTOL	55 °C	55 °C
Poff	2 W	2 W
PTO	90 W	90 W
PSB	3 W	3 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 22 Jun 2022

Supplementary Heater: PSUP	3.00 kW	2.90 kW
Annual energy consumption Q <sub>he</sub>	9057 kWh	10272 kWh