

This information was generated by the HP KEYMARK database on 31 Jul 2022

[Login](#)

Summary of	Alféa Excellia 14	Reg. No.	012-001
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	Alféa Excellia 14		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.5 kg		

## Model: Alféa Excellia 14

<b>Configure model</b>	
Model name	Alféa Excellia 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

<b>General Data</b>	
Power supply	1x230V 50Hz

### Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	13.50 kW	9.48 kW
El input	3.23 kW	3.95 kW
COP	4.18	2.40

### Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	148 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2022

COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh

## Model: Alféa Excellia A.I. 14

<b>Configure model</b>	
Model name	Alféa Excellia A.I. 14
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

<b>General Data</b>	
Power supply	1x230V 50Hz

### Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	13.50 kW	9.48 kW
El input	3.23 kW	3.95 kW
COP	4.18	2.40

### Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	148 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2022

COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh

## Model: Alféa Excellia Duo 14

<b>Configure model</b>	
Model name	Alféa Excellia Duo 14
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

<b>General Data</b>	
Power supply	1x230V 50Hz

### Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	13.50 kW	9.48 kW
El input	3.23 kW	3.95 kW
COP	4.18	2.40

### Average Climate



<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	148 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2022

COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	88 %
COP	2.25
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l

## Model: Alféa Excellia Duo A.I. 14

<b>Configure model</b>	
Model name	Alféa Excellia Duo A.I. 14
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

<b>General Data</b>	
Power supply	1x230V 50Hz

### Heating

<b>EN 14511-4</b>	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

<b>EN 14511-2</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Heat output	13.50 kW	9.48 kW
El input	3.23 kW	3.95 kW
COP	4.18	2.40

### Average Climate

<b>EN 12102-1</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

<b>EN 14825</b>		
	<b>Low temperature</b>	<b>Medium temperature</b>
$\eta_s$	148 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 31 Jul 2022

COP Tj = Tbiv	2.50	1.90
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	9.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.40	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Qhe	6824 kWh	8041 kWh

## Domestic Hot Water (DHW)

### Average Climate

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	88 %
COP	2.25
Heating up time	0:46 h:min
Standby power input	40.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	250 l